



Maiden Agartala site visit of Shri Jai Shankar, Managing Director, NETC

On 21.05.2025 MD, NETC along with Agartala team visited vulnerable tower locations on Palatana – Silchar section, severely affected due to Natural disaster in Aug 2024. The brief report are as follows.

Tower Loc. No. 200: Soil erosion observed near Leg "C", now only 8m from a steep 22m slope and proximity to the NH-08. Protection measures using RRM wall with geonet, as recommended by NERPC sub-group, discussed with Agartala TLM team.



Tower Loc. No. 217: Located 25m horizontally and 20m vertically below NH-08. Sinking and cracking of NH-08 has compromised tower foundation, causing bracing deformation, bending of 34 nos lattice pieces and mild buckling in Legs C and D. During the visit, measures on short term and long- term plan to ensure the safety of asset was deliberated, as recommended by NERPC.

